

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658

Jim Doyle, Governor Mary P. Burke, Secretary

April 30, 2007

STORMTECH, LLC DAVID J MAILHOT 20 BEAVER RD WETHERSFIELD CT 06190

Re: Description: STORMWATER TREATMENT DEVICE

Manufacturer: STORMTECH, LLC Product Name: STORMTECH

Model Number(s): ISOLATOR ROW, SC-310

Product File No: 20050165

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (6)(h) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2012.

This approval supersedes the approval issued on May 10, 2006, under product file number 20050165.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050165.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Prior to installation of this product, plans and specifications must be submitted to the department or to an
 approved agent municipality for review and approval in accordance with s. Comm 82.20 (1) of the Wis. Admin.
 Code. Written approval for the plans and specifications shall be obtained prior to installation of the product.
- Inspection and maintenance of this product must be performed at intervals specified by the manufacturer (S070104HP-5) or in accordance plan approval or s. Comm 82.21, whichever is more restrictive.
- When this product is installed an Isolator Row, the installation must be in accordance with the manufacturer's
 printed Design Manual (S070104HP-5), ch. Comm 82, plan approval under s. Comm 82.20 and product
 approval stipulations. When there is a conflict between manufacturer's installation instructions and plan
 approval or product approval stipulations, the plan approval or product approval stipulations will take
 precedence.
- This product must be permanently labeled identifying the manufacturer and model number (StormTech SC-310).

SBD-10564-E (N.10/97) File Ref: 05016502.DOC

STORMTECH, LLC Page 2 April 30, 2007 Product File No. 20050165

This product will produce an effluent that has less than 60 mg/L TSS for infiltration and 80% reduction of TSS when the influent and maintenance meets the conditions listed in Table 1, entitled StormTech Isolator Row Chamber Model SC-310.

Table 1 StormTech Isolator Row Chamber Model SC-740

Maximum	Suspended	Specific	Maintenance
Flow in	Solid	Gravity of	Interval in
cu. ft./sec.	Equivalent	Test Material	Years
0.3 cfs	US Silica Sand OK-110	2.65	2-4

(This table is based on influent having 200 mg/L TSS.)

- This product may be installed without a water proof membrane under the following conditions:
 - 1. The installation is for a subsurface detention system;
 - 2. The soils on which that detention system is placed have a maximum soil application rate of 0.2 gallons/square foot/day based upon morphological soil evaluation as listed in Comm Table 83.44-2 under the column for BOD5 and TSS > 30mg/L; and
 - 3. A geotextile fabric that meets the chamber manufactures specifications is place on the bottom of the product is required.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE Plumbing Product Reviewer phone: 608-266-6742 fax: 608-267-9566

e-mail: mike.beckwith@wisconsin.gov